

Building Project Inspection History Report



City of South Jordan

Building Division

1600 W Towne Center Drive
South Jordan, UT 84065
801-254-3742
<http://www.southjordancity.org>

Project #: 2013-16758

Address: 11294 BERG HOLLOW LN S, Apt. (805 W)

Project Description: KITCHEN REMODEL/ELECTRICAL & PLUMBING ONLY

Inspection

Schedule ID	Permit ID	Insp Sched Desc	Inspector	Group	Date	Time
151496	43721	*	Hardy, Jim	Building	4/18/2013	12:00 AM

Tasks

Inspection Type	Date	Time	Tasks / Results	Comments
Electric	4/18/2013	12:00 AM	Reschedule / Correction	- need 12 gauge wiring in kitchen.
Framing	4/18/2013	12:00 AM	Reschedule / Correction	- fire block drop in 1/2 bath. - fire block chase in kitchen. - provide clearance for fireplace.
Plumbing	4/18/2013	12:00 AM	Reschedule / Correction	- test DWV. - vent island sink.

Inspection

Schedule ID	Permit ID	Insp Sched Desc	Inspector	Group	Date	Time
151632	43721	*	Hardy, Jim	Building	4/22/2013	12:00 AM

Tasks

Inspection Type	Date	Time	Tasks / Results	Comments
Re-Electrical	4/22/2013	12:00 AM	None / Approved	
Re-Framing	4/22/2013	12:00 AM	Reschedule / Correction	- provide proper clearance for fireplace.
Re-Plumbing	4/22/2013	12:00 AM	Reschedule / Correction	- vent island sink.